

Map ID  
Direction  
Distance  
Elevation

MAP FINDINGS

EDR ID Number  
EPA ID Number

EO711  
East  
> 1  
1.008 mi.  
5324 ft.

SHELL STATION '  
3046 CONEY ISLAND AVE  
BROOKLYN, NY

NY Spills S125359433  
N/A

Site 2 of 8 in cluster EO

Relative:  
Higher

Actual:  
9 ft.

SPILLS:

Name: SHELL STATION '  
Address: 3046 CONEY ISLAND AVE  
City,State,Zip: BROOKLYN, NY  
Spill Number/Closed Date: 1905513 / Not Reported  
Facility ID: 1905513  
Facility Type: ER  
DER Facility ID: 257861  
Site ID: 593546  
DEC Region: 2  
Spill Cause: Equipment Failure  
Spill Class: Not reported  
SWIS: 2401  
Spill Date: 2019-08-26  
Investigator: HRPATEL  
Referred To: Not reported  
Reported to Dept: 2019-08-26  
CID: Not reported  
Water Affected: Not reported  
Spill Source: Commercial/Industrial  
Spill Notifier: Tank Tester  
Cleanup Ceased: Not reported  
Cleanup Meets Std: False  
Last Inspection: Not reported  
Recommended Penalty: False  
UST Trust: False  
Remediation Phase: 1  
Date Entered In Computer: 2019-08-26  
Spill Record Last Update: 2019-09-06  
Spiller Name: Not reported  
Spiller Company: SHELL STATION  
Spiller Address: Not reported  
Spiller Company: 999  
Contact Name: CHARLES PEDANO  
DEC Memo: "8/26/19-Zhune spoke to Charles Pedano from Island Pump and tank. Charles said they went to Shell station to test the product lines. and the line test failure. tomorrow they will investigate and determine whether or not the line failed. 8/29/19-Line letter sent to: Mr. Adam Wolf Bill Wolf Petroleum Corporation 100 Jericho quadrangle Suite 209 Jericho quadrangle Suite 209, Jericho, NY 11753  
09/06/19-Hiralkumar Patel. alternate address: 3046-3058 Coney Island Ave, 176-186 Neptune Ave PBS #: 2-339776, 2-480444, 2-610665 as per PBS #: 2-339776, site had ten (10) 550 gal gasoline, one (1) 550 gal #2 oil and one (1) 4,000 gal gasoline USTs, all closed prior to Mar. 1991. as per PBS #: 2-610665, the site has one (1) 275 gal waste oil AST, converted to non-regulated use. as per PBS #: 2-480444, the site has following tanks: - one (1) 275 gal #2 oil AST, in-service, installed in Mar. 1990 - one (1) 275 gal waste oil AST, in-service, installed in Mar. 1990 - one (1) 275 gal motor oil AST, in-service, installed in May 2012 - four (4) 4,000 gal gasoline USTs, in-service, installed in Mar. 1990 other spills : 8903465, 9303507 spill #: 8903465 was reported on 07/06/1989 as gasoline tank failed a test. as per notes, air sparge/soil vapor extraction system was in operation from July 1996 to Mar. 2000. five monitoring wells were

Map ID  
Direction  
Distance  
Elevation

MAP FINDINGS

Site

Database(s)

EDR ID Number  
EPA ID Number

Remarks:

installed/monitored. case closed based on available data. spill #:  
9303507 was reported on 06/17/1993 as 1 gal of gasoline was spilled.  
case closed. Coney Island-Neptune Gasoline Corp. \*\*property owner\*\*  
DEC Zhune sent letter on 08/29/19 requiring investigation for line  
test failure. report due by 09/30/19. \*\*report due on 09/30/19.\*\*"  
"gas line test failure. Investigation pending"

All Materials:

Site ID: 593546  
Operable Unit ID: 1341131  
Operable Unit: 01  
Material ID: 2350981  
Material Code: 0050A  
Material Name: freon  
Case No.: Not reported  
Material FA: Other  
Quantity: Not reported  
Units: Not reported  
Recovered: Not reported  
Oxygenate: Not reported